



Consumer Confidence Report 2012

Drinking Water Quality Report *For The* **CITY OF BASTROP**

PWS # TX0110001

Annual Water Quality Report for the period of
January 1 to December 31, 2012

Interim Director: Trey Job
Interim Superintendent: Curtis Hancock

**Water Conservation and Special Programs
Coordinator: Kimberly McClain**

***En Español** – Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (512) 332-8960.*

Water & Wastewater Department
512-332-8960

Public Participation Opportunities

The Water Department is part of the Bastrop City Government. You are invited to attend City Council meetings on the 2nd & 4th Tuesday of every month. Regular sessions begin at 6:15 p.m. in the Council Chambers, 1311 Chestnut Street. Contact the City Secretary at (512) 332-8800 for details.

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water. For more information about the City of Bastrop's Water and Wastewater Department, please visit us on the web at www.cityofbastrop.org.

WATER SOURCES:

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water **before treatment** include: microbes, inorganic contaminants, pesticides, herbicides, radioactive contaminants, and organic chemical contaminants.


Where Do We Get Our Drinking Water?



The City of Bastrop is Ground Water Under Direct Influence of Surface Water. The TCEQ completed an assessment of your source water and results indicate that some of your sources are susceptible to certain contaminants. The sampling requirements for your water system are based on this susceptibility and previous sample data. Any detection of these contaminants may be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system, please contact us at (512) 332-8960.

This report is a summary of the quality of the water we provide our customers. The analysis was made by using the data from the most recent U.S. Environmental Protection Agency (EPA) required tests and is presented in the attached pages. We hope this information helps you become more knowledgeable about what's in your drinking water.

The tables below list all of the federally regulated or monitored contaminants which have been found in your drinking water. The U.S. EPA requires water systems to test for up to 97 contaminants.



DEFINITIONS

- Maximum Contaminant Level (MCL)** - The highest permissible level of a contaminant in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- Maximum Contaminant Level Goal (MCLG)** - The level of a contaminant in drinking water below which there is no known or expected health risk. MCLGs allow for a margin of safety.
- Maximum Residual Disinfectant Level (MRDL)** - The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control and microbial contaminants.
- Maximum Residual Disinfectant Level Goal (MRDLG)** - The level of drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.
- Treatment Technique (TT)** - A required process intended to reduce the level of a contaminant in drinking water.
- Action Level (AL)** - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

ABBREVIATIONS

- NTU** - Nephelometric Turbidity Units
- MFL** - million fibers per liter (a measure of asbestos)
- pCi/l** - picocuries per liter (a measure of radioactivity)
- ppm** - parts per million, or milligrams per liter (mg/l)
- ppb** - parts per billion, or micrograms per liter (ug/l)
- ppt** - parts per trillion, or nanograms per liter
- ppq** - parts per quadrillion, or picograms per liter

Inorganic Contaminants

| Year or Range | Contaminant | Highest Level Detected | Range of Levels Detected | MCLG | MCL | Unit of Measure | Source of Contaminant |
|---------------|-------------|------------------------|--------------------------|------|-----|-----------------|--|
| 2011 | Arsenic | 2.1 | 2.1 - 2.1 | 0 | 10 | ppb | Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes. |
| 2012 | Asbestos | 0.38 | 0.38 - 0.38 | 7 | 7 | MFL | Decay of asbestos cement water mains; Erosion of natural deposits. |
| 2011 | Barium | .117 | .117 - .117 | 2 | 2 | ppm | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits. |
| 2012 | Fluoride | 0.44 | 0.44 - 0.44 | 4 | 4 | ppm | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories. |
| 2012 | Nitrate | 3 | 2.47 - 2.94 | 10 | 10 | ppm | Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits. |
| 2011 | Selenium | 3.1 | 3.1 - 3.1 | 50 | 50 | ppb | Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines. |

Nitrate Advisory - Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask advice from your health care provider.

Maximum Residual Disinfectant Level

| Year | Contaminant | Average Level | Minimum Level | Maximum Level | MRDL | MRDLG | Unit of Measure | Source of Contaminant |
|------|-------------------------|---------------|---------------|---------------|------|-------|-----------------|--|
| 2012 | Chlorine Residual, Free | 1.02 | .50 | 2.20 | 4 | <4 | ppm | Disinfectant used to control microbes. |

Turbidity: Not Required.

Total Coliform: Reported Monthly Tests Found NO COLIFORM BACTERIA.

Fecal Coliform: Reported Monthly Tests Found NO FECAL COLIFORM BACTERIA.

Regulated Contaminants (Disinfectants and Disinfection Byproducts)

| Year | Contaminant | Highest Level Detected | Range of Levels Detected | MCLG | MCL | Unit of Measure | Source of Contaminant |
|------|------------------------|------------------------|--------------------------|-----------------------|-----|-----------------|---|
| 2012 | Total Haloacetic Acids | 10 | 8.9 - 11.2 | No Goal for the Total | 60 | ppb | Byproduct of drinking water disinfection. |
| 2012 | Total Trihalomethanes | 45 | 41.4 - 48.8 | No Goal for the Total | 80 | ppb | Byproduct of drinking water disinfection. |

Not all sample results may have been used for calculating the Highest Level Detected because some results may be part of an evaluation to determine where compliance sampling should occur in the future.

Unregulated Contaminants: NOT REPORTED OR NONE DETECTED

LEAD and COPPER

| Year (Range) | Contaminant | The 90 th Percentile | Number of Sites Exceeding Action Level | Action Level | Unit of Measure | Source of Contaminant |
|--------------|-------------|---------------------------------|--|--------------|-----------------|---|
| 2012 | Lead | 4.17 | 1 | 15 | ppb | Corrosion of household plumbing systems; erosion of natural deposits. |
| 2012 | Copper | 1.34 | 2 | 1.3 | ppm | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservations. |

Required Additional Health Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. This water supply is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

RADIOACTIVE CONTAMINANTS

| Year (Range) | Contaminant | Highest Level Detected | Range of Levels Detected | MCLG | MCL | Unit of Measure | Source of Contaminant |
|--------------|----------------------|------------------------|--------------------------|------|-----|-----------------|---|
| 2010 | Beta/Photon Emitters | 5.3 | 5.3 – 5.3 | 0 | 50 | pCi/L* | Decay of natural and man-made deposits. |

*EPA considers 50 pCi/L to be the level of concern for beta particles.

SYNTHETIC ORGANIC CONTAMINANTS (Including pesticides and herbicides)

| Year (Range) | Contaminant | Highest Level Detected | Range of Levels Detected | MCLG | MCL | Unit of Measure | Source of Contaminant |
|--------------|-------------|------------------------|--------------------------|------|-----|-----------------|--|
| 2012 | Altrazine | 0.15 | 0 – 0.15 | 3 | 3 | Ppb | Runoff from herbicide used on row crops. |

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the Water and Wastewater Department at (512) 332-8960.

ALL DRINKING WATER MAY CONTAIN CONTAMINANTS.

Drinking water, including bottled water may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (1-800-426-4791).





CONTACT US

| | |
|---|--------------|
| Account Information/Billing Questions | 512-332-8830 |
| Report Water Main Breaks/Sewer Stops (24 hours) | 512-332-8960 |
| Water Quality Inquiries/Complaints | 512-332-8960 |

VISIT US

| | | |
|--|-----------|---|
| Customer Service Office 1311 Chestnut Street Bastrop, Texas 78602 | OR | Water & Wastewater Department 300 Water Street Bastrop, Texas 78602 |
| Monday – Friday 8:00 a.m. to 4:00 p.m. Drive-thru open 7:00 a.m. to 4:30 p.m. | | Monday – Friday 7:00 a.m. to 4:00 p.m. |



SPECIAL NOTICE

You may be more vulnerable than the general population to certain microbial contaminants, such as Cryptosporidium, in drinking water. Infants, some elderly or immunocompromised persons such as those undergoing chemotherapy for cancer; those who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care provider. Additional guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are available from the Safe Drinking Water Hotline (1-800-426-4791).

City of Bastrop
Water & Wastewater Department
P.O. Box 427
Bastrop, Texas 78602

